



OUDTSHOORN DRINKWATER RESULTATE

Julie 2017

MUNISIPALITEIT UMASIPALA MUNICIPALITY
Wes-Kaap Intshona-Koloni Western Cape

255 Oudtshoorn 6620 - Tel. (044) 2033000 - Fax: (044) 2033104 - Epos: post@oudtmun.co.za

Meting / Gehalteparameter	OUDTSHOORN										DYSELSDORP		DE RUST		SANS 241	
	Bergoord Raubenheimer Dam	Bergoord Jeugsentrum	Kerk Str Reservoir	Nuwe Oos	Wesbank	Ou Oos	Rioolwerke Lab	Van. Riebeeck Str. 4	Bridgeton Grond	Caves Aftree Oord	Rioolwerke Kraan	Munisipale Kantoor	Rou Water	Blomnek Alwyn str. 114		Munisipale Kantoor
pH	7.16	6.64	7.12	7.07	7.53	7.11	6.78	7.13	6.39	6.88	7.16	7.26	7.37	6.82	7.20	5.0-9.5
Oënskynlike kleur (mg/L Pt)	67	42	56	47	48	42	52	44	41	108	0	5	75	56	56	<20
Turbiditeit (NTE)	2.84	2.09	3.25	2.30	2.78	2.29	2.68	2.28	2.02	5.26	0.43	0.21	4.70	2.27	2.56	<1
Elektriese Geleiding (mS/m)	9.74	5.07	10.28	10.16	10.74	10.42	10.41	10.52	11.04	10.10	29.8	29.5	3.62	6.76	6.47	<150
Yster (mg/L as Fe)	0.20	0.18	0.17	0.18	0.18	0.18	0.18	0.17	0.17	0.27	0.02	0.02	0.71	0.48	0.51	Aesthetic <0.3 Chronic health <2.0
Mangaan (Mn)					0.037							0.011			0.026	0.1-1.0
Totale chloorresidu (mg/L)		0.03	0.06	0.14	0.18	0.40	0.18	0.12	0.12	0.64	0.80	1.00		0.05	0.04	-
Vry chloorresidu (mg/L)		0.03	0.06	0.09	0.18	0.18	0.09	0.86	0.07	0.44	0.60	0.80		0.03	0.03	-
Totale kolivorme (aantal/100mL)		31	6	0	0	0	3	130	410	0	0	0		111	101	<10
E. Coli (aantal/100mL)		17	0	0	0	0	0	0	90	0	0	0		2	10	0

G/M = geen monster

Monster geneem deur: Sheldon Booyen
Datum geneem: 05/07/2017
Datum ontvang in lab: 05/07/2017
Chemiese Analiese gedoen deur: Ilse-Ann Oliphant