



# OUTDSHOORN DRINKWATER RESULTATE

## Mei 2016

MUNISIPALITEIT UMASIPALA MUNICIPALITY  
Wes-Kaap Intshona-Koloni Western Cape

255 Oudtshoorn 6620 - Tel. (044) 2033000 - Fax: (044) 2033104 - Epos: [post@oudtmun.co.za](mailto:post@oudtmun.co.za)

Meting / Gehalteparameter	OUTDSHOORN											DYSELSDORP		DE RUST		SANS 241
	Bergoord Raubenheimer Dam	Bergoord Jeugsentrum	Kerk Str Reservoir	Nuwe Oos	Wesbank	Ou Oos	Rioolwerke Lab	Van. Riebeeck Str. 4	Bridgeton Grond	Caves Aftree Oord	Rioolwerke Kraan	Munisipale Kantoor	Rou Water	Blomnek Alwyn str. 114	Munisipale Kantoor	
pH	7.47	7.47	7.53	7.50	7.42	7.57	7.54	7.64	7.08	7.59	8.27	8.80	7.52	6.79	6.89	5.0-9.5
Turbiditeit (NTE)	0.73	0.33	1.26	0.59	0.61	0.82	0.90	0.44	0.51	0.85	0.13	0.23	0.62	0.71	0.61	<1
Oënskylike kleur (mg/L Pt)	23	23	24	23	14	18	24	22	14	26	8	8	29	15	22	<20
Kalsium (mg/L as CaCO <sub>3</sub> )					G/R							G/R			G/R	375
Magnesium (mg/L as CaCO <sub>3</sub> )					G/R							G/R			G/R	290
Totale Hardheid as mg/L CaCO <sub>3</sub>					G/R							G/R			G/R	-
Elektriese Geleiding (mS/m)	6.81	2.00	7.06	6.97	7.11	7.05	7.47	7.35	7.78	6.77	18.49	19.48	2.23	3.98	4.62	<150
Yster (mg/L as Fe)	0.09	0.04	0.08	0.07	0.08	0.10	0.10	0.08	0.08	0.08	0.03	0.02	0.12	0.09	0.01	<0.2
Aluminium (mg/L as Al)			G/R									G/R			G/R	
Mangaan (Mn)					G/R							G/R			G/R	0.1-1.0
Totale chloorresidu (mg/L)		0.04	0.05	0.12	0.05	0.04	0.05	0.03	0.03	0.08	0.06	0.12		0.59	0.49	-
Vry chloorresidu (mg/L)		0.07	0.06	0.04	0.05	0.06	0.02	0.00	0.01	0.06	0.03	0.12		0.63	0.35	-
Totale kolivorme (aantal/100mL)		125	0	47	125	290	0	4	3	460	0	0		0	0	0
E. Coli (aantal/100mL)		0	0	0	0	0	0	0	0	0	0	0		0	0	0

G/R = geen reagens

Monster geneem deur:

Johan Uys

Datum geneem:

25/05/2016

Datum ontvang in lab:

25/05/2016

Chemiese Analiese gedoen deur:

Ilse-Ann Oliphant